



CITY OF TOPEKA

Contracts and Procurement Division
 City Hall, 215 SE 7th St., Room 60
 Topeka, KS 66603

procurement@topeka.org
 Tel: 785-368-3749

Date:	Wednesday, March 25, 2026		
Event Number:	Bid 18 Street & Storm Sewer Impr Project Central Highland Park Neighborhood 841099.09, 501107.10		
Question #	Type One Question per line Below		
Example Q1	How many inches in one foot?		
Example A1:	12 inches		
Q1.	The unclassified excavation quantities appear to be high. Do they include the pavement removal volume?		
A1.	The Unclassified Excavation quantity erroneously included the Pavement Removal volume. We have updated the DOC020, DOC330, and Electronic Bid form to account for the correction. Sheet 02 of the plan set is also updated. Please note that Pavement quantities A1.1 and A2.1 increased as a part of our quantity audit, and is also included in the Addendum #2 which shall be made available on the portal.		
Q2.	The plans call out Type I curb & gutter on sheet 4, but is not included in the proposal. Please clarify.		
A2.	The Curb & Gutter type listed on sheet 4 was erroneously listed as Type I. We have updated DOC020, DOC330, and Electronic Bid form to account for the correction. Sheet 04 of the plan set is also updated. However, this section of curb is actually to be poured monolithically to the partial Valley Gutter replacements. The combined quantities follow the City of Topeka method of payment for constructing Valley Gutter, using both Valley gutter and the Type II curb length. These items are listed in Addendum #2 which shall be made available on the portal.		
Q3.			
Q4.			
Q5.			
Q6.			
Q7.			
Q8.			
Q9.			
Q10.			
Q11.			
Q12.			
Q13.			
Q14.			
Q15.			
Q16.			
Q17.			